



A P P R O V A L S ®

## Certificate of Suitability

**Certificate No.:** SAA170053

**Certificate Holder:** Zhejiang Benyi Electrical Co., Ltd.  
Wenzhou Bridge Industrial Zone,  
Beibaixiang Yueqing,  
(Feice Explosion-Proof Electric Co., Ltd.)  
P.R. China

**Class Description:** Non-Declared  
**Product Description:** PV Switch Disconnecter

**Brand Name:**   
**Model No.:** BYH-32  
**Markings:** 1000Vdc Max, 50A Max  
ta:-40 to +85°C, IP66  
**Standard:** IEC 60947-1 Ed 5.2  
IEC 60947-3 Ed 3.2  
**Conditions:** Nil

**Certification Mark:** SAA170053 or RCM

**Date First Registered:** 19 January 2017  
**Date of Expiry:** 19 January 2022




For and on Behalf of  
SAA Approvals Pty Ltd

SAA Approvals Pty Ltd as accredited by JAS-ANZ under ISO/IEC 17065 certifies in accordance with the SAA Approvals Electrical Product Safety Certification Scheme that the product nominated in this certificate complies with standard/s listed.

When using the RCM the requirements of all relevant parts of AS/NZS 4417 applicable to the article must be fulfilled.

For SAA Contact Details and to verify this Certificate go to:  
[www.saaapprovals.com.au](http://www.saaapprovals.com.au)

JAS-ANZ



[www.jas-anz.org/register](http://www.jas-anz.org/register)



Issued: 19-01-17 170053/1



A P P R O V A L S ®

## Certificate of Suitability

\* Addendum \*

**Certificate No.:** SAA170053

**Date of Issue:** 19 January 2017

**Class Description:** Non-Declared

**Product Description:** PV Switch Disconnecter

**General Modification:**

Use of alternative trade name **ZJ·BENY**

<b>Additional Models</b>	<b>Description</b>
BYH-32M1	Similar to BYH-32 except with PV-connector
BYH-32M2	Similar to BYH-32M1 except with different PV-connector.
BYT-32	Similar to BYH-32 except rated 1200Vdc
BYT-32M1	Similar to BYT-32 except with PV-connector.
BYT-32M2	Similar to BYT-32M1 except with different PV-connector.
BYT.1-32	Similar to BYT-32 except without enclosure and for panel mounting.
BYT.2-32	Similar to BYT-32 except without enclosure and for DIN rail mounting.


For and on Behalf of  
SAA Approvals Pty Ltd

SAA Approvals Pty Ltd as accredited by JAS-ANZ under ISO/IEC 17065 certifies in accordance with the SAA Approvals Electrical Product Safety Certification Scheme that the product nominated in this certificate complies with standard/s listed.

When using the RCM the requirements of all relevant parts of AS/NZS 4417 applicable to the article must be fulfilled.

For SAA Contact Details and to verify this Certificate go to:  
[www.saaapprovals.com.au](http://www.saaapprovals.com.au)

JAS-ANZ



[www.jas-anz.org/register](http://www.jas-anz.org/register)



Issued: 19-01-17 170053/2